

14. Adopt "An Ordinance Amending Chapter 7.70 of the Santa Cruz County Code Relating to Wells and Borings" (Approved in concept January 28, 2025) ()



County of Santa Cruz Board of Supervisors

Agenda Item Submittal

From: Clerk of the Board

Subject: Adopt "An Ordinance Amending Chapter 7.70 of the SCCC Relating to Wells and Borings"

Meeting Date: February 11, 2025

Formal Title: Adopt "An Ordinance Amending Chapter 7.70 of the Santa Cruz County Code Relating to Wells and Borings" (Approved in concept January 28, 2025)

Recommended Actions

1. Adopt "An Ordinance Amending Chapter 7.70 of the Santa Cruz County Code Relating to Wells and Borings" as approved in concept on January 28, 2025.

Executive Summary

n/a

Discussion

On January 28, 2025, the Board approved the ordinance in concept and scheduled it for second reading/final adoption on February 11, 2025.

Financial Impact

Information on the financial and budgetary impacts of this item. Must include GL key and object.

Strategic Initiatives

N/A

Submitted By:

Juliette Rezzato, Chief Deputy Clerk of the Board

Recommended By:

Carlos J. Palacios, County Administrative Officer

Artificial Intelligence Acknowledgment:

Artificial Intelligence (AI) did not significantly contribute to the development of this agenda item.



DS

Page 1/18

BEFORE THE BOARD OF SUPERVISORS
OF THE COUNTY OF SANTA CRUZ, STATE OF CALIFORNIA

ORDINANCE NO. 5470

**ORDINANCE AMENDING CHAPTER 7.70 OF THE SANTA CRUZ COUNTY CODE RELATING TO
WELLS AND BORINGS**

The Board of Supervisors of Santa Cruz County hereby finds and declares the following:

WHEREAS, Santa Cruz County Code Chapter (SCCC) 7.70, Wells (SCCC 7.70), includes various policies for the siting, design, and use of wells to protect groundwater and natural resources, as also provided for in the Santa Cruz County General Plan and Local Coastal Program (LCP); and

WHEREAS, in 2014, the State of California adopted the Sustainable Groundwater Management Act, which requires local entities to sustainably manage groundwater to prevent overdraft, protect water quality, maintain groundwater levels and prevent depletion of surface water; and

WHEREAS, recent judicial decisions have required counties to consider impacts on public trust resources and the environment when issuing well permits; and

WHEREAS, California Water Code Section 13801 and related provisions require oversight of the construction and destruction of soil borings to protect groundwater quality; and

WHEREAS, amendments to SCCC 7.70 have been prepared in order to be consistent with the State policies and guidance; and

WHEREAS, the County's Environmental Coordinator has determined that the proposed amendments to SCCC 7.70 would improve protection of the environment and are exempt from further consideration under the California Environmental Quality Act pursuant to 14 Cal. Code Regs. §§ 15308 and 15061(b)(3) and a Notice of Exemption has been prepared; and

WHEREAS, the County of Santa Cruz Planning Commission held a public hearing on October 23, 2024, and adopted a resolution recommending that the Board of Supervisors adopt the proposed ordinance amending SCCC 7.70; and

WHEREAS, the Board of Supervisors of the County of Santa Cruz finds that the proposed amendments to SCCC 7.70 are consistent with all other provisions of the SCCC and the General Plan/LCP, and with State law;

NOW THEREFORE, the Board of Supervisors of the County of Santa Cruz ordains as follows:

SECTION I

Chapter 7.70 of the Santa Cruz County Code is hereby amended to read as follows:

Chapter 7.70 WELLS AND BORINGS

Sections:

- 7.70.010 Purpose of provisions.**
- 7.70.015 Applicability.**
- 7.70.020 Definitions.**
- 7.70.030 Permit—Required—Issuance.**
- 7.70.040 Permit—Expiration.**
- 7.70.050 Permit—Suspension or revocation.**
- 7.70.060 Licensed contractor required.**
- 7.70.070 State and Federal reporting regulations.**
- 7.70.080 Inspections.**
- 7.70.090 Technical standards.**
- 7.70.100 Well abandonment and destruction—Inactive well.**
- 7.70.105 Soil Borings.**
- 7.70.107 Stormwater Infiltration Devices.**
- 7.70.110 Resource protection.**
- 7.70.120 Soquel Creek service area restrictions.**
- 7.70.130 Groundwater emergencies.**
- 7.70.140 Abatement—Investigation.**
- 7.70.150 Abatement generally.**
- 7.70.160 Nuisance—Abatement of safety hazard.**
- 7.70.170 Amendments.**
- 7.70.180 Violations.**
- 7.70.190 Recording notices of violations.**
- 7.70.180 Promulgation of policies.**

7.70.010 Purpose of provisions.

The purposes of this chapter are to:

(A) Provide for the location, construction, repair, and reconstruction of all wells, including geothermal heat exchange wells, cathodic protection wells, test wells, monitoring wells, and soil borings, to the end that the groundwater of this County will not be polluted or contaminated and that water obtained from such wells will be suitable for the purpose for which used and will not jeopardize the health, safety or welfare of the people of this County;

(B) Provide for the destruction of any abandoned wells, monitoring wells, test wells, geothermal heat exchange wells, cathodic protection wells, or soil borings, which may serve as a conduit for movement of contaminants, or which are found to be a public nuisance, to the end that such a well or boring will not cause pollution or contamination of groundwater or otherwise jeopardize the health, safety or welfare of the people of this County;

- (C) Protect surface and ground water resources, and related public trust resources; and
- (D) Implement policies of the County General Plan and the Local Coastal Program Land Use Plan, the California Sustainable Groundwater Management Act, and local groundwater sustainability plans.

7.70.015 Applicability.

Except as otherwise provided in this chapter, this chapter shall apply to all wells and soil borings within the unincorporated area of the County, except the following:

- (A) Oil and gas wells, or geothermal wells constructed under the jurisdiction of the Department of Conservation, except those wells converted to use as water wells;
- (B) Wells or bores used for the purpose of dewatering excavation during construction, or stabilizing hillsides or earth embankments; or
- (C) Seepage Pits.

7.70.020 Definitions.

As used in this chapter, the following words shall have the meanings provided in this section:

- (A) "Abandoned well" means any well whose original purpose and use have been permanently discontinued or which is in such a state of disrepair that it cannot be used for its original purpose. A well is considered abandoned when it has not been used for a period of one year, unless the Owner demonstrates their intent to use the well again for supplying water or other associated purposes and the well is maintained as an inactive well.
- (B) "Abatement" means the construction, reconstruction, repair or destruction of a well so as to eliminate the possibility that such well could pollute or contaminate groundwater.
- (C) "Cathodic protection well" means any artificial excavation in excess of 50 feet in depth constructed by any method for the purpose of installing equipment or facilities for the protection electronically of metallic equipment in contact with the ground, commonly referred to as "cathodic protection."
- (D) "Contamination" or "contaminated" means an impairment of the quality of water to a degree that water contains contaminants in excess of the applicable standards currently promulgated by the California State Water Resources Control Board.
- (E) "Contamination hazard" is the hazard to a well when the water entering a well contains, or that within a reasonable period of time it will likely contain, contaminants in excess of the applicable standards currently promulgated by the California State Water Resources Control Board.
- (F) "Control Zone" means an area around a groundwater management project where well drilling is prohibited. Control Zones are defined by a water district and/or groundwater sustainability agency in order to comply with State health and safety requirements as required by Section 60320.200(e) of Title 22 of the California Code of Regulations.

- (G) "Geothermal heat exchange well" means any uncased artificial excavation, by any method, that uses the heat exchange capacity of the earth for heating and cooling, and in which excavation the ambient ground temperature is 30 degrees Celsius (86 degrees Fahrenheit) or less, and which excavation uses a closed-loop fluid system to prevent the discharge or escape of its fluid into surrounding aquifers or other geologic formations. Geothermal heat exchange wells include ground source heat pump wells. Such wells or boreholes are not intended to produce water or steam.
- (H) "Groundwater" means water beneath the surface of the earth within the zone below the water table in which the soil is completely saturated with water.
- (I) "Groundwater Extraction Concern Area" means an area designated by the Health Officer where groundwater availability is limited due to inadequate supply or poor quality, or where construction of additional wells may cause significant adverse impacts on groundwater levels, surface water flow, or seawater intrusion.
- (J) "Health Officer" means the County Health Officer or their authorized representative.
- (K) "Inactive well" means a well not routinely operated but capable of being made an operating well with a minimum of effort.
- (L) "Karst" means a type of underlying geology that may have the presence of subsurface fissures, caverns, sinkholes or other features resulting from dissolution of limestone or marble that could lead to the rapid subsurface movement of water. Known areas of karst are shown on maps maintained by the Health Officer and other underground karst areas may be discovered in the process of drilling.
- (M) "Monitoring or observation well" means any artificial excavation by any method for the purpose of obtaining groundwater, vadose zone, or other subsurface data, including groundwater levels, groundwater quality, and soil vapor quality.
- (N) "Order of abatement" means both mandatory and prohibitory orders requiring or prohibiting one or more acts; the term also includes those orders effective for a limited as well as an indefinite period of time, and includes modifications or restatements of any order.
- (O) "Owner" means the person who is the well owner, who is also the owner of the property on which the well is located. The well owner shall be responsible for the use of the well on the property on which the well is located and on any other properties that are served by the well. The well owner shall maintain control over the use of the well through agreements with other property owners, lessees or others that use the well. All users of the well shall be held jointly and severally liable for complying with the provisions of this chapter and with any conditions or restrictions imposed as a condition of a permit to construct the well.
- (P) "Pajaro groundwater protection zone" means the area in the Pajaro Valley Groundwater Basin within the boundaries of the Pajaro Valley Water Management Agency.
- (Q) "Person" means any person, firm, corporation or governmental agency.

(R) "Pollution" means an alteration of the quality of water to a degree that unreasonably affects:

- (1) Such waters for beneficial uses; or
- (2) Facilities which serve such beneficial uses.

Pollution may include contamination or the presence of contaminants in amounts less than the applicable standards currently promulgated by the California State Water Resources Control Board.

(S) "Public Trust Resources" mean resources, such as fisheries, wildlife, aesthetics, and navigation, which are held in trust for the public.

(T) "Seepage pit" means a large diameter borehole for the disposal of sewage.

(U) "Soil Boring" or "Boring" means an excavation or boring constructed to obtain information on subsurface conditions.

(V) "Stormwater infiltration device" or "dry well" means a trench or large diameter borehole for the infiltration of stormwater.

(W) "Structure" means anything constructed or erected which requires a location on the ground, including a building, but not including a fence or a deck less than 18 inches in height.

(X) "Sustainable yield" means the annual draft of water that can be withdrawn from an aquifer without producing some significant unreasonable, undesirable result such as chronic lowering of groundwater levels, reduction of storage, seawater intrusion, degraded water quality, or depletion of interconnected surface water. Where applicable, sustainable yield would be as defined by the Groundwater Sustainability Agency in their Groundwater Sustainability Plan or Alternative.

(Y) "Test well" means a well constructed for the purpose of obtaining information needed to design a well prior to its construction. Test wells are cased and can be converted to observation or monitoring wells and under certain circumstances to production wells.

(Z) "Tier" means the type of well application and the level of review and conditions that will be needed for approval based on the proposed volume of pumping, type of water use, proposed increase in water use, the aquifer characteristics and the potential for impact on streams, public trust resources, nearby wells, groundwater sustainability, control zones, and/or the environment.

(AA) "Water Well" means a well constructed to extract groundwater. Types of water wells include:

- (1) "Agricultural well" means a water well used to supply water for commercial agricultural purposes, including so-called "livestock wells."
- (2) "Community well" means a water well used to supply water for domestic purposes in public water systems or State small water systems as defined in Section 116275 of the Health and Safety Code.
- (3) "De Minimis Well" means a water well used to supply water for domestic needs of up to four individual primary dwelling units, as defined in SCCC 13.10.700-D, using a total of less than 2 acre-feet per year. An approved accessory dwelling unit is not considered a separate primary dwelling unit for this purpose. De minimis domestic use may include up to one half acre of non-commercial residential irrigated landscaping and gardening per primary dwelling unit.

- (4) "Industrial Well" means a water well used to supply industry or a commercial use on an individual basis.
 - (5) "New Well" means a water well that will serve a new or significantly expanded use, which represents an increased extraction of groundwater.
 - (6) "Replacement Well" means a water well that will serve an existing use with no significant increase in water use and will replace an existing water source such as a spring or well that is to be destroyed.
 - (7) "Supplemental Well" means a water well that that will support an existing use with no overall increase in water use. The existing source could be a shared well or other well that will be maintained as a backup source.
- (BB) "Well" means any artificial excavation, constructed by any method, for the purpose of extracting water or injecting water into the underground, evaluating subsurface conditions, providing for geothermal heat exchange or cathodic protection, or any other subsurface installation that may create a potential conduit or preferential pathway for movement of water or contaminants to groundwater.
- (CC) "Well reconstruction" or "well repair" means certain work done to an existing well in order to restore its production, replace defective casing, seal off certain strata or surface water, or similar work, not to include the cleaning out of sediments or surging, or maintenance to the pump or appurtenances where the integrity of the annular seal or water-bearing strata is not violated.

7.70.030 Permit—Required—Issuance.

- (A) No person shall, within the unincorporated area of the County, construct, repair, reconstruct or destroy any well, abandoned well, cathodic protection well, geothermal heat exchange well, monitoring well, test well, or soil boring unless a written permit has first been obtained from the Health Officer as provided in this chapter, and the work conforms to the conditions of such permit and this chapter. Applications for such permits shall be made on the forms provided for that purpose and in accordance with procedures established by the Health Officer.
- (B) A permit shall be required to change the use of a well when the change would: cause the well to no longer meet the definition of a de minimis well, as specified in Section 7.70.020(AA)(3); place the well in a different Tier, as specified in Section 7.770.110(E); or result in increased use beyond that specified in an approved well construction permit. Applications for such permits shall be made on the forms provided for that purpose and in accordance with procedures established by the Health Officer.
- (C) A coastal development permit shall be required for any well proposed to be drilled in the Coastal Zone unless it qualifies for an exemption, exclusion, or de minimis waiver, as provided in SCCC 13.20.
- (D) Well permits for wells that meet the Tier 1, Tier 2 or Tier 3 requirements of SCCC 7.70.110(E) are ministerial unless the issuance of the well permit requires one or more discretionary approvals pursuant to SCCC 13.20, 16.20, 16.30, 16.32, 16.40, or 16.42.
- (E) For proposed wells or changes in use that do not meet the Tier 1, Tier 2, or Tier 3 requirements of SCCC 7.70.110(E), the Health Officer may require a report evaluating the potential impact of the proposed well use to nearby wells, surface waters, public trust resources, or groundwater sustainability that is to be prepared and submitted to the Health Officer prior to issuance of the permit. The report

shall be prepared by a professional geologist, engineering geologist, or professional engineer and shall at a minimum include conclusions and data supporting the conclusions including a description of site and regional geology, subsurface conditions, strata, direction and rate of groundwater flow, locations of nearby water wells, and construction details for those wells as can be determined based on existing data. The report shall describe proposed well construction methods and other measures to be taken to prevent adverse impacts of the well. The Health Officer shall deny a permit or require specific construction requirements in order to prevent significant adverse impacts on nearby wells, surface water, public trust resources, or groundwater sustainability as defined by the applicable groundwater sustainability agency.

(F) Each application shall be accompanied by a filing fee set by resolution of the Board of Supervisors. No part of the fee shall be refundable.

(G) Permit applications shall be transmitted to the water system, water district, and/or groundwater sustainability agency that has jurisdiction over the parcel where the proposed well will be located or that could be impacted by the proposed well or change in use. Those entities shall have ten (10) business days to provide any comment, request additional information, or identify any other requirements that must be met for the construction and use of the proposed well within their jurisdiction.

(H) Within twenty (20) business days after receipt of a complete application including all studies or additional information requested by the Health Officer, the County Health Officer shall either grant or deny the permit. Permits shall be issued only if the proposed well is in compliance with all applicable County codes and will be located on a legal lot of record. Permits may be approved with specific requirements to comply with this chapter.

(I) At the discretion of the Health Officer and prior to the commencement of any work, an emergency approval may be granted for any work for which a permit is required by this chapter if the Health Officer determines that a sudden, unexpected occurrence demands immediate action to prevent loss of or damage to life, health, property, or essential public services, and it is not practical to obtain a permit before the commencement of the work. The Health Officer may request, at the applicant's expense, verification by a professional geologist, engineering geologist, or professional engineer of the nature of and solutions to the emergency situation. In all cases in which emergency work is necessary, a permit shall be applied for within three (3) business days after commencement of the work. If emergency approval by the Health Officer is not requested or an application is not submitted within the specified time, the work shall be considered a violation of this chapter. The applicant for a permit for any such emergency work shall demonstrate that all work performed is in compliance with the technical standards of SCCC 7.70.090.

(J) Any person who commences or completes any work or action for which a permit is required without first having obtained a permit therefor shall, if subsequently permitted to obtain a permit, pay double the permit fee established by resolution of the Board of Supervisors for such work. If such well does not meet the requirements of this chapter, the Health Officer shall require the well to be destroyed under permit.

7.70.040 Permit—Expiration

(A) Each permit issued pursuant to this chapter shall expire and become null and void if the work authorized thereby has not been completed within two (2) years following the issuance of the permit.

(B) Upon expiration of any permit issued pursuant thereto, no further work may be done in connection with construction, repair, reconstruction or destruction of a well, monitoring well, test well, geothermal heat exchange well, cathodic protection well, or soil boring unless and until a new permit for such purpose is secured in accordance with the provisions of this chapter.

(C) The Health Officer may authorize renewal of a permit for an additional year upon payment of 20 percent of the application fee within 180 calendar days after the date of permit expiration.

7.70.050 Permit—Suspension or revocation

(A) A permit issued under this chapter may be revoked or suspended by the Health Officer as provided in this section if they determine that a violation of this chapter exists, that written notice has been directed to the permittee specifying the violation, and that the permittee has failed or neglected to make necessary adjustments within thirty (30) calendar days after receiving such notice.

(B) A permit may be revoked or suspended by the Health Officer if they determine at a hearing held by the Health Officer for such purpose that the person to whom any permit was issued pursuant to this chapter has obtained the same by fraud or misrepresentation; provided, that notice of the time, place, and purpose of such hearing is given to the permittee at least five (5) calendar days prior thereto.

(C) The suspension or revocation of any permit shall not be effective until notice thereof in writing is provided to the permittee.

7.70.060 Licensed contractor required.

Construction, reconstruction, repair, and destruction of all wells covered by this chapter shall be performed by a contractor with a C-57 contracting license or an equivalent license issued by the Department of Professional and Vocational Standards.

7.70.070 State and Federal reporting regulations.

Nothing contained in this chapter shall be deemed to release any person from compliance with the provisions of Article 3, Chapter 10, Division 7 of the California Water Code or any other State or Federal reporting regulations.

7.70.080 Inspections.

(A) Upon receipt of an application, an inspection of the location of the well, test well, geothermal heat exchange well, or cathodic protection well shall be made by the Health Officer prior to issuance of a well permit. Inspection of monitoring well and soil boring locations prior to permit issuance may be made by the Health Officer.

(B) The person responsible for construction, reconstruction, or destruction of any well shall notify the Health Officer at least two (2) business days prior to commencement of work. All work shall be subject to inspection by the Health Officer to ensure compliance with all the requirements of this chapter.

(C) The Health Officer shall make inspection of the well seal and completed work to determine compliance with the well standards. After work has been completed, the person performing the work shall file with the Health Officer a notice of completed work or a copy of the California Department of Water Resources well report.

7.70.090 Technical standards.

Standards for the construction, repair, reconstruction of, or destruction of wells, abandoned wells, monitoring wells, test wells, geothermal heat exchange wells, and cathodic protection wells shall be as set forth in Chapter II of the Department of Water Resources Bulletin No. 74-81, "Water Well Standards" (December 1981), the Department of Water Resources Bulletin No. 74-90, "Water Well Standards" (June 1991), and Chapter II of the Department of Water Resources Bulletin No. 74-1, "Cathodic Protection Well Standards" (March 1973), or as subsequently revised or supplemented, which are incorporated by reference in this chapter, with the following modifications:

- (A) The minimum horizontal distance between wells and potential sources of contamination shall be:
- (1) 100 feet between subsurface sewage leaching fields, septic tanks, animal enclosures, accumulations of manure, or other sources of contamination as identified by the Health Officer. If the property to be served by the proposed well is already developed, lesser distances than that listed above may be acceptable where physical conditions preclude compliance with the specified minimum separation distances and if a sanitary seal at least 100 feet deep is installed and the existing well is destroyed under permit. Lesser separation distances must be approved by the Health Officer on a case-by-case basis.
 - (2) 150 feet to seepage pit.
 - (3) 150 feet between a community well and subsurface sewage dispersal system less than 10 feet deep.
 - (4) 200 feet between a community well and a subsurface sewage dispersal system greater than 10 feet deep. A greater separation up to 600 feet may be required in order to maintain a 2-year time of travel.
- (B) No well shall be constructed within 50 feet horizontal from the property line of the property owner authorizing construction of the well. This setback may be reduced to not less than five feet horizontal if the owner of the adjacent property authorizes a reduction in setback or if the Health Officer determines area on the adjacent property within 100 feet of the proposed well is unsuitable for installation of an onsite sewage disposal system.
- (C) No well shall be constructed within 5 feet horizontal from any structure.
- (D) All wells shall be constructed so that the well seal shall be a minimum of 50 feet below the surface of the ground. If usable water is only available less than 50 feet from the surface, the Health Officer may allow the seal depth to be reduced to not less than 20 feet if the well construction, site conditions, and the characteristics of the underlying geology will preclude the downward movement of contaminants into the aquifer.

(E) Drilling fluids and other drilling materials used in connection with well construction shall not be allowed to discharge onto streets or into waterways and shall not be allowed to discharge off the parcel on which the well is constructed onto adjacent properties; provided, that adjacent property may be used temporarily for the discharge of such fluids and materials pursuant to written agreement with the owner(s) of the adjacent property; and provided, that such fluids and materials are removed and cleaned up within thirty (30) days of completion of the well drilling.

(F) Water generated during test pumping of wells shall be dispersed or disposed of in a manner which will not cause excessive erosion or turbidity, in violation of SCCC 16.22 or 16.24.

(G) Subsections (A), (B) and (D) of this section do not apply to monitoring wells.

(H) New wells that supply water to a public water system must use the methodology, as required by the California State Water Resources Control Board Drinking Water Source Assessment and Protection Program, to determine the 10-year time-of-travel groundwater protection zone. For other wells, e.g., de minimis wells, the default groundwater protection zone minimum radius of 1,000 feet for a five-year time-of-travel shall be used to protect the drinking water source from chemical contamination. If sites with existing soil and/or groundwater contamination are present within the 10-year zone for public water systems, or five-year zones for other wells such as domestic wells, and the Health Officer determines that there is a potential for a contamination hazard to be created, the Health Officer may require that a report evaluating the potential for contamination or pollution of the well from existing nearby activities be prepared prior to issuance of a well permit. The report shall be prepared by a professional geologist, engineering geologist, or professional engineer and shall at a minimum include conclusions and data supporting the conclusions including without limitations a description of site and regional geology, subsurface conditions, strata, direction and rate of groundwater flow, locations of vicinity water wells, and construction details for those wells as can be determined based on existing data. The report shall describe proposed well construction methods and other measures to be taken to prevent contamination or pollution of the well and surrounding aquifers. The Health Officer shall deny a well permit or require specific construction requirements in order to prevent contamination or pollution of the well or surrounding aquifers.

(I) The Health Officer shall have the power to allow minor variances from the standards set forth in this section so as to prevent unnecessary hardship or injustice and at the same time accomplish the general purpose and intent of the standards and the resource protection policies of the County's General Plan and Local Coastal Program Land Use Plan. In no case may a variance be granted that constitutes a special privilege.

(J) The Health Officer may establish standards and procedures for the construction and destruction of wells or soil borings to be used for evaluation, monitoring or remediation of sites with known or threatened contamination.

7.70.100 Well abandonment and destruction—Inactive well.

(A) A well is considered abandoned when it has not been used for a period of one (1) year and it is not being maintained as a monitoring well or an inactive well.

(B) The Owner of an inactive well shall properly maintain the well in such a way that:

- (1) The well is covered such that the cover is watertight and cannot be removed, except with the aid of equipment or the use of a tool.
- (2) The well is marked so it can clearly be seen.
- (3) The area surrounding the well is kept clear of brush or debris.
- (4) The pump shall be maintained in the well with an approved power supply, except for temporary removal for repair or replacement.

(C) On abandonment of a well, or on the order of the Health Officer, a well shall be destroyed under permit by methods described in Bulletin Nos. 74-81 and 74-90, or as subsequently revised or supplemented, which are incorporated by reference in this chapter with the following modifications.

- (1) All open wells shall be immediately capped with a fixed cover until the well is properly destroyed.
- (2) The well shall be completely sealed with acceptable sealing material from the true bottom of the well up to five (5) feet of the surface. The casing should be cut off five (5) feet below the surface, with the excavation backfilled by compacted native material.
- (3) Acceptable sealing materials are 23 sack neat cement, 10 sack cement grout, or any other compound approved by the Health Officer.
- (4) A tremie pipe or other method approved by the Health Officer shall be used to pump the sealing material into the well under pressure if the well is over 30 feet deep or more than three (3) feet of standing water is present in the well.
- (5) Where there is potential for movement of contaminants between the outside of the well casing and the borehole, the Health Officer shall require perforation of the casing at certain depths, overdrilling, and/or other techniques which will seal the annular space outside the well casing as needed to prevent the migration of contaminants.
- (6) For destruction of wells where groundwater quality problems are known to exist, the Health Officer may require that destruction be designed and supervised by a professional geologist, professional engineer, or other qualified person. The proposed method of destruction shall be subject to approval by the Health Officer prior to performance of the work.

(D) A well which has any defects which will allow the impairment of quality of water in the well or in the water-bearing formations penetrated shall be destroyed and may not be designated inactive. In areas where groundwater problems are known to exist, abandoned wells that penetrate and/or are perforated in two or more aquifers shall be destroyed and may not be designated inactive.

(E) To prevent the contamination of underground water supplies through open wells, no person shall knowingly permit the existence on premises in their ownership or possession or control of any well opening or entrance which is not sealed or secured in such a way as to prevent the introduction of contaminants.

(F) No person shall knowingly permit on premises in their ownership or possession or control the existence of any abandoned well that constitutes a known or probable pathway for the vertical movement of contaminants.

7.70.105 Soil Borings.

The Health Officer shall establish policies and procedures for installation and destruction of soil borings so that such soil borings do not create a conduit or preferential path for movement of contaminants into groundwater.

7.70.107 Stormwater Infiltration Devices.

The Health Officer shall establish policies and procedures for installation and destruction of stormwater infiltration devices so that such installations do not create a conduit or preferential path for movement of contaminants into groundwater.

7.70.110 Resource protection.

(A) Within the Pajaro groundwater protection zone, and in other areas where water contains constituents in excess of the applicable standards currently promulgated by the California Department of Health or where a monitoring agency or groundwater sustainability agency has determined that seawater intrusion is threatened, all wells shall be constructed in such a manner that the well does not provide a conduit for contamination or pollution between aquifers.

(1) In such areas, the Health Officer shall impose a requirement for new wells which penetrate more than one aquifer that an electric log device measuring spontaneous potential and resistivity be run in the uncased well borehole by a certified hydrologist, geohydrologist or other qualified person approved by the Health Officer. Based on the data obtained from the electric log and the geologic log of the well, the certified hydrologist, geohydrologist or other qualified person approved by the Health Officer shall identify strata containing poor water quality and recommend to the well driller the location and specifications of the seal or seals needed to prevent the entrance of poor-quality water or its migration into other aquifers.

(2) The well shall be completed with the seal or seals specified by the certified hydrologist, geohydrologist or other such qualified person approved by the Health Officer. The person performing and evaluating the electric log shall submit a written report to the Health Officer.

(B) Prior to completion of a well, a water sample shall be collected and tested for total dissolved solids, chloride, nitrate, and any other constituent which the Health Officer has reason to believe could be present in the well. The sample results shall be submitted to the Health Officer. If any constituent exceeds drinking water standards, the Health Officer shall require testing and sealing of the well pursuant to subsection (A) of this section. If standards for the proposed use cannot be met or the aquifer cannot be adequately protected from contamination or pollution, the Health Officer shall require that the well be destroyed. The Health Officer may require additional water quality testing upon completion of the well.

(C) Each application for a new, supplemental, or replacement well shall accurately specify the parcels proposed to be served, the type of land uses to be served, the estimated annual water use for non-de minimis wells, and the presence of any existing wells which also serve those uses. The Health Officer may require documentation to support the water use estimates provided.

(D) For new, supplemental, or replacement wells, the following measures will be taken to ensure that groundwater is put to beneficial use and is not wasted:

(1) A water use efficiency evaluation shall be completed, with recommendations for increased efficiency of use identified. The Health Officer shall require that all reasonable measures be implemented.

(2) In lieu of performing an efficiency evaluation as required by subsection (D)(1) of this section, the Owner may provide verification that conservation measures to achieve efficient interior and exterior water use have been taken.

(3) For new uses that will be developed after the well is completed, the Owner shall provide certification that conservation measures will be implemented as a part of the new use.

(4) Requirements for water efficiency evaluations and acceptable conservation measures shall be established by policy by the Health Officer. The Health Officer may specify maximum annual water use based on Tier and mitigation of potential impacts.

(5) For non-de minimis wells, a meter shall be installed and maintained to accurately measure water use and usage shall be reported annually to the Health Officer, according to procedures established by the Health Officer. The cost of meter installation, maintenance, and reporting shall be borne by the Owner. As a condition of the approval of a well with limitations on water use, the Owner shall enter into an agreement with the County of Santa Cruz acknowledging and accepting the requirements for limitations on water use. A notice of water use limitation shall be recorded by the Health Officer with the County Recorder's Office on the deed of the property with an approved well with limitations on water use.

(6) The Health Officer may require the Owner to provide information to confirm that the required conservation measures are being maintained. If such information is not provided or water usage is not being reported, the Health Officer may conduct an inspection to observe the meter and/or verify that water conservation measures are being maintained. Inspections shall be conducted at reasonable times and the inspector shall first make a reasonable effort to contact the Owner or occupant(s) of the premises. If the inspection requires the entry into a building or an area that is designed for privacy, then prior permission shall be obtained from the Owner or occupant(s). If permission is denied, then a site inspection warrant shall be obtained.

(7) If the usage information or the results of a site inspection show that the Owner is not in compliance with this chapter or with the requirements of the permit, the Health Officer shall require that corrective measures be taken.

(E) Each application for a new, supplemental, or replacement well shall be evaluated and specific measures may be required to ensure that the well will not have significant adverse impacts on groundwater sustainability, nearby wells, surface water, or the environment. The level of evaluation and required measures will depend on the Tier in which the well falls, based on the type of well, the location, and the aquifer characteristics. The Health Officer shall establish specific criteria and procedures for assigning the Tier and the extent of required evaluation and protective measures. Such criteria shall be adopted by the Board of Supervisors by resolution. The Health Officer may deny applications for Tier 4 wells that will have a significant adverse impact on groundwater sustainability, nearby wells, surface water, or the environment.

(1) Tier 1 will include de minimis wells and non-domestic wells using less than 2 acre-feet per year that do not require any discretionary review under other chapters of the SCCC and meet the minimum standards for preventing impacts on streams and nearby wells based on aquifer characteristics, well characteristics, depth of well seal, and location.

(2) Tier 2 will include supplemental and replacement non-de minimis wells with no significant increase in water use and meet the minimum standards for preventing impacts on streams and nearby wells based on aquifer characteristics, well characteristics, depth of well seal, and location.

(3) Tier 3 will include new non-de minimis wells serving new uses that will pump less than 50 acre-feet per year and wells that do not meet the Tier 1 or Tier 2 requirements. Tier 3 wells must also meet the minimum Tier 3 requirements for stream depletion and nearby well drawdowns.

(4) Tier 4 will include wells that do not meet the Tier 1, 2, or 3 requirements, are in a control zone, are in specified Tier 4 Groundwater Extraction Concern Areas, or are wells that could adversely affect the sustainability of a groundwater basin.

(F) A well permit shall not be approved for a well that poses a significant conflict with the implementation of a groundwater replenishment project or other project specified in an adopted groundwater sustainability plan as determined by the affected water district or groundwater sustainability agency.

(G) For non de minimis wells, if a well is proposed in a known karst area or if karst is encountered during the drilling process, further drilling shall be suspended, and the Health Officer shall evaluate whether a well can be completed without causing adverse impacts on groundwater resources, surface waters, or other water users. The Health Officer shall establish procedures for such evaluation and may require analysis at the expense of the applicant by a professional geologist familiar with occurrence and movement of water in karst landscapes. Recommendations may include procedures for destroying the borehole without adversely affecting subsurface conditions. For de minimis wells that are proposed in karst or that encounter karst, the Health Officer shall be notified prior to well completion, and additional protective measures may be required as determined by the Health Officer.

(H) Wells located in designated groundwater extraction concern areas will be subject to additional requirements to ensure reliability, adequate quality, and limited resource impact, as established by the Health Officer's policy. Approval of wells located in Tier 4 groundwater extraction concern areas shall be discretionary and may not be granted if resource impacts cannot be mitigated.

(I) If a groundwater sustainability agency has required metering or other conditions for an existing, new, replacement, or supplemental well, the Owner shall abide by those requirements. If the usage information or the results of a site inspection show that the Owner is not in compliance with those requirements, the Health Officer shall require that corrective measures be taken.

(J) New, supplemental, or replacement wells shall not be constructed within a designated control zone for a groundwater management project.

(K) A permit shall be required to change the use of a well when the change would: cause the well to no longer meet the definition of a de minimis well, as specified in Section 7.70.020(AA)(3); place the well in a different Tier, as specified in Section 7.770.110(E); or result in increased use beyond that specified in an approved well construction permit. Such permit would be processed according to provisions in Section 7.70.030.

7.70.120 Soquel Creek service area restrictions.

(A) Findings. The Board of Supervisors finds and determines that:

- (1) Several reports have been prepared which indicate the potential for seawater intrusion into the Santa Cruz Mid-County Groundwater Basin; and
- (2) There is need for careful monitoring and management of the groundwater basin; and
- (3) Careful management is greatly facilitated by restricting the number of new wells and requiring that new development be supplied by Soquel Creek Water District, a public agency empowered to carry out monitoring and management efforts; and

- (4) Construction of new wells within the water district service area increases the potential public health hazard of cross-connection between public and private water systems; and
- (5) Current County General Plan policies require that new development within the urban services line be served by a public water system.

(B) Well Construction within the Soquel Creek Water District Service Area. The construction of new wells shall be prohibited on parcels that are within 200 feet horizontal of a water distribution line of the Soquel Creek Water District.

(C) New Well Construction—Exceptions. The following new well construction shall not be subject to the prohibition of this section:

- (1) Replacement of existing wells;
- (2) Construction of a well for commercial agricultural use, monitoring and observation purposes, geothermal heat exchange or cathodic protection;
- (3) Well construction on parcels which cannot be served by the Soquel Creek Water District, as determined by the Environmental Health Director based on a written statement from the District clearly demonstrating their inability to provide service; or
- (4) Construction of a well by any public water purveyor or state small water system.

7.70.130 Groundwater emergencies.

(A) A groundwater emergency shall be declared in areas demonstrated to be experiencing a groundwater overdraft exceeding the sustainable yield in order to prevent further depletion and degradation of water resources where such degradation threatens the public health, safety and welfare of the community, or the ability of a groundwater sustainability agency to meet its minimum thresholds, and where the Board of Supervisors finds that adequate measures are not already being taken to alleviate the overdraft situation. The emergency shall have no effect on drilling of monitoring, soil borings, geothermal heat exchange, or cathodic protection wells.

(B) Declaration. A declaration of a groundwater emergency shall be made by the Board of Supervisors only after a public hearing. Such an emergency shall be declared by resolution of the Board of Supervisors after the public hearing to consider all relevant information such as, but not limited to, the most current groundwater study, recommendations of groundwater sustainability agencies, water purveyors, and the Water Advisory Commission and only after the following findings can be made:

- (1) The designated area is experiencing a groundwater overdraft exceeding the long-term sustainable yield;
- (2) The creation of new wells or the expansion of existing wells will significantly increase the demand on the affected aquifer and thereby increase the overdraft;
- (3) The continuation of the overdraft will result in further depletion and degradation of the water resource that can lead to, but is not limited to, impairment of the aquifer, allowing the ingress of low-quality or saline water, or other undesirable results; and
- (4) Adequate measures are not being taken by water users and other responsible agencies to alleviate the overdraft situation.

(C) Immediate Measure to Alleviate. In areas where a groundwater emergency is declared, the Board of Supervisors shall take action to establish water conservation measures, to limit construction of new wells, and to regulate pumping from or expansion of existing wells, in order to prevent further depletion

and degradation of the affected aquifer. In taking these actions, the Board of Supervisors shall give consideration to the seasonal needs of agriculture including, but not limited to, the following factors.

- (1) Agriculture's need to repair, maintain, and replace existing wells serving existing agricultural use acreage;
- (2) Well construction for agricultural use to serve existing agricultural acreage when new parcels are created due to change in legal ownership, split parcels or parcels created by change in zoning laws, or other governmental regulations; and
- (3) The different water requirements of agricultural crops.

(D) Long-Term Measures to Alleviate. The Board of Supervisors shall initiate actions such as, but not limited to, joint power agreements with other agencies with the goal of finding permanent solutions to the groundwater problem.

(E) Duration. A groundwater emergency and the measures enacted to alleviate the emergency shall remain in effect until rescinded as established in subsection (G) of this section.

(F) Annual Review. The establishment of a groundwater emergency and all actions to alleviate the emergency shall be reviewed by the Board of Supervisors within one (1) year of the date of enactment of the measures at a public hearing to decide whether the declaration of emergency shall remain in effect.

(G) Rescinding. A groundwater emergency shall be rescinded by resolution of the Board of Supervisors after a public hearing when one of the following findings is made:

- (1) Alternative water sources which compensate for the existing overdraft and supply the affected area are developed;
- (2) A groundwater management program is implemented which will allow for additional development without contribution to groundwater overdraft; or
- (3) The Board of Supervisors determines that new information is available which indicates that the technical data upon which the original findings were based is no longer valid.

7.70.140 Abatement—Investigation.

The Health Officer may, upon reasonable cause to believe that an abandoned well, a cathodic protection well, or any other well or soil boring that may potentially either contaminate or pollute groundwater, investigate the situation to determine whether such potential threat to groundwater quality or present nuisance does, in fact, exist. The Health Officer shall have the power upon presenting identification to any person apparently in control of the premises to enter upon any such premises between the hours of 8:00 a.m. and 6:00 p.m. to discover or inspect any thing or condition which may indicate such a nuisance or threat to groundwater quality. The Health Officer may examine such premises, things or conditions, take such samples and make such tests as needed, and take other steps reasonably necessary for the proper investigation and determination of whether a nuisance or threat to groundwater quality exists. The burden, including costs, of these activities, analyses, and reports shall be borne by the responsible party.

7.70.150 Abatement generally.

Whenever the Health Officer determines that an abandoned well, a cathodic protection well, or any other well or soil boring is presently polluting or contaminating groundwater, or poses a substantial

threat to groundwater quality, or is otherwise not in compliance with the provisions of this chapter, the Health Officer shall abate the well as a nuisance in accordance with the provisions of SCCC 1.14.

7.70.160 Nuisance—Abatement of safety hazard.

This chapter shall not affect the right of the County to abate as a public nuisance pursuant to Article 9, Chapter 1, Division 1, Title 5, of the Government Code (commencing with Section 50230) any abandoned well, cathodic protection well, or other well or soil boring which presents a safety hazard.

7.70.170 Amendments.

Any revision to this chapter which applies to the Coastal Zone shall be reviewed by the Executive Director of the California Coastal Commission to determine whether it constitutes an amendment to the Local Coastal Program. When an ordinance revision constitutes an amendment to the Local Coastal Program, such revision shall be processed pursuant to the hearing and notification provisions of SCCC 13.03, and shall be subject to approval by the California Coastal Commission.

7.70.180 Violations.

(A) In the event of a violation of the provisions of this chapter or the conditions of any permit issued under this chapter, the Owner or permittee shall be given notice of such violation and a reasonable time to correct the violation.

(B) Whenever the Health Officer visits a property to ensure compliance with a permit condition or a notice to correct violation, and the condition or requirement is not satisfied or the violation has not been corrected, the Owner shall be subject to a violation reinspection fee, the amount to be established by resolution of the Board of Supervisors.

(C) Reimbursement of the costs of investigation and enforcement of a violation including any fines or fees related to the violation shall be borne by the responsible party.

7.70.190 Recording notices of violations.

Whenever the Health Officer has knowledge of a violation of any of the provisions of this chapter or any condition of a permit issued under this chapter, the Health Officer may provide a notice of intent to record a notice of violation to the Owner of the property on which the violation is located. Notice shall be provided by posting on the property and by mail at the address shown on the latest assessment roll or at any other address of the Owner known to the Health Officer. The notice shall state that within twenty (20) calendar days of the date of the notice, the Owner may request a meeting with the Health Officer to present evidence that a violation does not exist. In the event that a meeting is not requested and the violation has not been corrected, or, in the event that after consideration of the evidence the Health Officer determines that a code violation in fact exists, the Health Officer may record a notice of code violation in the Office of the County Recorder. At the request of any affected property owner, the Health Officer shall issue a notice of expungement of code violation upon correction of any violation noticed hereunder. The notice of expungement may be recorded by the affected property owner at their expense. The decision of the Health Officer shall be final.

7.70.200 Promulgation of policies.

Any policy, specification, or procedure which the Health Officer is authorized by this chapter to adopt shall be in writing with copies made available to the public. Such policies, specifications, or procedures shall be made available to the public thirty (30) days before their implementation by the Health Officer.

SECTION II

The Board of Supervisors hereby finds and determines that, on the basis of the whole record before it, the amendments to SCCC Chapter 7.70 are exempt from consideration under the California Environmental Quality Act because they will result in improved protection of the environment (Class 8 categorical exemption, 14 Cal. Code Regs. §15308) and because it can be seen with certainty that there is no possibility the activity will have a significant effect on the environment (common-sense exemption, 14 Cal. Code Regs. §15061(b)(3)).

SECTION III


Should any section, clause, or provision of this Ordinance be declared by the courts to be invalid, the same shall not affect the validity of the Ordinance as a whole, or parts thereof, other than the part so declared to be invalid.

SECTION IV

This ordinance shall take effect on July 1, 2025, or upon certification by the State Coastal Commission whichever event occurs last.

PASSED AND ADOPTED this 11th day of February, 2025, by the Board of Supervisors of the County of Santa Cruz by the following vote:

AYES: Supervisors Koenig, De Serpa, Cummings, Martinez and Hernandez
 NOES: None
 ABSENT: None
 ABSTAIN: None


DocuSigned by:

 309EB769DA614E4...

Felipe Hernandez 2/12/2025
 Chairperson of the Board of Supervisors

DocuSigned by:

 466B074F3141450...
 Attest: Juliette Rezzato 2/12/2025
 Clerk of the Board

Approved as to form:

DocuSigned by:

 2/5/2025
 F0F6FD189D784BF...
 Office of County Counsel



Certificate Of Completion

Envelope Id: D2BD84E1-D0B6-4F38-B925-6AACD6968197	Status: Completed
Subject: Ordinance Amendment Water Advisory Chapter 7.70 (25-1191) 2/11/2025 BOS	
Source Envelope:	
Document Pages: 18	Signatures: 1
Certificate Pages: 5	Initials: 0
AutoNav: Enabled	Envelope Originator:
Envelopeld Stamping: Enabled	HSA Admin Processing
Time Zone: (UTC-08:00) Pacific Time (US & Canada)	701 Ocean Street
	Santa Cruz, CA 95060
	hsa.adminprocessing@santacruzcountyca.gov
	IP Address: 63.194.190.170

Record Tracking

Status: Original	Holder: HSA Admin Processing	Location: DocuSign
2/5/2025 10:43:55 AM		
	hsa.adminprocessing@santacruzcountyca.gov	
Security Appliance Status: Connected	Pool: FedRamp	
Storage Appliance Status: Connected	Pool: County of Santa Cruz	Location: DocuSign

Signer Events	Signature	Timestamp
John Nguyen	<div>DocuSigned by:  F0F6FD189D784BF...</div>	Sent: 2/5/2025 10:51:25 AM
JOHN.NGUYEN@SANTACRUZCOUNTYCA.GOV		Viewed: 2/5/2025 10:51:44 AM
Lead Assistant County County Counsel		Signed: 2/5/2025 10:54:30 AM
Security Level: Email, Account Authentication (None)	Signature Adoption: Uploaded Signature Image	
	Using IP Address: 73.92.113.14	

Electronic Record and Signature Disclosure:
Accepted: 6/12/2024 8:53:19 AM
ID: cff2bd5b-d3a4-40f2-aa61-cc2de5bbd9e3

In Person Signer Events	Signature	Timestamp
Editor Delivery Events	Status	Timestamp
Agent Delivery Events	Status	Timestamp
Intermediary Delivery Events	Status	Timestamp
Certified Delivery Events	Status	Timestamp

Carbon Copy Events	Status	Timestamp
CBD eSignature	<div>COPIED</div>	Sent: 2/5/2025 10:54:31 AM
cbd.esignature@santacruzcountyca.gov		Viewed: 2/5/2025 11:07:20 AM
County of Santa Cruz		
Security Level: Email, Account Authentication (None)		
Electronic Record and Signature Disclosure: Accepted: 6/20/2024 3:08:48 PM ID: 4b7794de-1393-406f-a9a3-56a92d4b90d7		
Sierra Ryan	<div>COPIED</div>	Sent: 2/5/2025 10:54:32 AM
Sierra.Ryan@santacruzcountyca.gov		
Security Level: Email, Account Authentication (None)		
Electronic Record and Signature Disclosure: Accepted: 8/9/2024 9:21:30 AM ID: cc5ec81e-4117-4985-8706-a9fc0ef2149d		

Ordinance 5470

Carbon Copy Events	Status	Timestamp
HSA ADMIN HSA.AdminProcessing@santacruzcountyCA.GOV Security Level: Email, Account Authentication (None) Electronic Record and Signature Disclosure: Accepted: 4/24/2024 2:34:11 PM ID: 00c89360-1e1f-479f-918e-15cefaa8da5a	COPIED	Sent: 2/5/2025 10:54:32 AM Resent: 2/5/2025 10:54:35 AM

Witness Events	Signature	Timestamp
----------------	-----------	-----------

Notary Events	Signature	Timestamp
---------------	-----------	-----------

Envelope Summary Events	Status	Timestamps
Envelope Sent	Hashed/Encrypted	2/5/2025 10:51:25 AM
Certified Delivered	Security Checked	2/5/2025 10:51:44 AM
Signing Complete	Security Checked	2/5/2025 10:54:30 AM
Completed	Security Checked	2/5/2025 10:54:32 AM

Payment Events	Status	Timestamps
----------------	--------	------------

Electronic Record and Signature Disclosure
--

ELECTRONIC RECORD AND SIGNATURE DISCLOSURE

From time to time, County of Santa Cruz (we, us or Company) may be required by law to provide to you certain written notices or disclosures. Described below are the terms and conditions for providing to you such notices and disclosures electronically through the DocuSign system. Please read the information below carefully and thoroughly, and if you can access this information electronically to your satisfaction and agree to this Electronic Record and Signature Disclosure (ERSD), please confirm your agreement by selecting the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

Getting paper copies

At any time, you may request from us a paper copy of any record provided or made available electronically to you by us. You will have the ability to download and print documents we send to you through the DocuSign system during and immediately after the signing session and, if you elect to create a DocuSign account, you may access the documents for a limited period of time (usually 30 days) after such documents are first sent to you. After such time, if you wish for us to send you paper copies of any such documents from our office to you, you will be charged a \$0.00 per-page fee. You may request delivery of such paper copies from us by following the procedure described below.

Withdrawing your consent

If you decide to receive notices and disclosures from us electronically, you may at any time change your mind and tell us that thereafter you want to receive required notices and disclosures only in paper format. How you must inform us of your decision to receive future notices and disclosure in paper format and withdraw your consent to receive notices and disclosures electronically is described below.

Consequences of changing your mind

If you elect to receive required notices and disclosures only in paper format, it will slow the speed at which we can complete certain steps in transactions with you and delivering services to you because we will need first to send the required notices or disclosures to you in paper format, and then wait until we receive back from you your acknowledgment of your receipt of such paper notices or disclosures. Further, you will no longer be able to use the DocuSign system to receive required notices and consents electronically from us or to sign electronically documents from us.

All notices and disclosures will be sent to you electronically

Unless you tell us otherwise in accordance with the procedures described herein, we will provide electronically to you through the DocuSign system all required notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you during the course of our relationship with you. To reduce the chance of you inadvertently not receiving any notice or disclosure, we prefer to provide all of the required notices and disclosures to you by the same method and to the same address that you have given us. Thus, you can receive all the disclosures and notices electronically or in paper format through the paper mail delivery system. If you do not agree with this process, please let us know as described below. Please also see the paragraph immediately above that describes the consequences of your electing not to receive delivery of the notices and disclosures electronically from us.

How to contact County of Santa Cruz:

You may contact us to let us know of your changes as to how we may contact you electronically, to request paper copies of certain information from us, and to withdraw your prior consent to receive notices and disclosures electronically as follows:

To contact us by email send messages to: nada.algharib@santacruzcounty.us

To advise County of Santa Cruz of your new email address

To let us know of a change in your email address where we should send notices and disclosures electronically to you, you must send an email message to us at nada.algharib@santacruzcounty.us and in the body of such request you must state: your previous email address, your new email address. We do not require any other information from you to change your email address.

If you created a DocuSign account, you may update it with your new email address through your account preferences.

To request paper copies from County of Santa Cruz

To request delivery from us of paper copies of the notices and disclosures previously provided by us to you electronically, you must send us an email to nada.algharib@santacruzcounty.us and in the body of such request you must state your email address, full name, mailing address, and telephone number. We will bill you for any fees at that time, if any.

To withdraw your consent with County of Santa Cruz

To inform us that you no longer wish to receive future notices and disclosures in electronic format you may:

- i. decline to sign a document from within your signing session, and on the subsequent page, select the check-box indicating you wish to withdraw your consent, or you may;
- ii. send us an email to nada.algharib@santacruzcounty.us and in the body of such request you must state your email, full name, mailing address, and telephone number. We do not need any other information from you to withdraw consent.. The consequences of your withdrawing consent for online documents will be that transactions may take a longer time to process..

Required hardware and software

The minimum system requirements for using the DocuSign system may change over time. The current system requirements are found here: <https://support.docusign.com/guides/signer-guide-signing-system-requirements>.

Acknowledging your access and consent to receive and sign documents electronically

To confirm to us that you can access this information electronically, which will be similar to other electronic notices and disclosures that we will provide to you, please confirm that you have read this ERSD, and (i) that you are able to print on paper or electronically save this ERSD for your future reference and access; or (ii) that you are able to email this ERSD to an email address where you will be able to print on paper or save it for your future reference and access. Further, if you consent to receiving notices and disclosures exclusively in electronic format as described herein, then select the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

By selecting the check-box next to 'I agree to use electronic records and signatures', you confirm that:

- You can access and read this Electronic Record and Signature Disclosure; and
- You can print on paper this Electronic Record and Signature Disclosure, or save or send this Electronic Record and Disclosure to a location where you can print it, for future reference and access; and
- Until or unless you notify County of Santa Cruz as described above, you consent to receive exclusively through electronic means all notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you by County of Santa Cruz during the course of your relationship with County of Santa Cruz.

Certificate Of Completion

Envelope Id: 1B504209-AE9C-41A5-B0F9-2555D7EFDD27

Status: Completed

Subject: Complete with Docusign: Ordinance 5470 Amending Santa Cruz County Code Chapter 7.70 Wells (DOC-...

Source Envelope:

Document Pages: 23

Signatures: 2

Envelope Originator:

Certificate Pages: 5

Initials: 0

CBD eSignature

AutoNav: Enabled

Stamps: 1

701 Ocean Street

Envelopeld Stamping: Enabled

Santa Cruz, CA 95060

Time Zone: (UTC-08:00) Pacific Time (US & Canada)

cbd.esignature@santacruzcountyca.gov

IP Address: 63.194.190.100

Record Tracking

Status: Original

Holder: CBD eSignature

Location: DocuSign

2/12/2025 11:58:58 AM

cbd.esignature@santacruzcountyca.gov

Security Appliance Status: Connected

Pool: FedRamp

Storage Appliance Status: Connected

Pool: County of Santa Cruz

Location: DocuSign


Signer Events

Felipe Hernandez

Felipe.Hernandez@santacruzcountyca.gov

Security Level: Email, Account Authentication (None)

Signature

DocuSigned by:

309EB769DA614E4...

Timestamp

Sent: 2/12/2025 12:03:35 PM

Viewed: 2/12/2025 12:58:54 PM

Signed: 2/12/2025 12:59:23 PM

Signature Adoption: Uploaded Signature Image

Using IP Address: 63.249.104.22

Electronic Record and Signature Disclosure:

Accepted: 7/17/2023 11:30:46 AM

ID: 2a2f0d4d-8f3b-4197-9c0c-4b7e9be9c82a

Juliette Rezzato

Juliette.Rezzato@santacruzcountyca.gov

Chief Deputy Clerk of the Board of Supervisors
County of Santa Cruz

Security Level: Email, Account Authentication (None)

DocuSigned by:

466B074F3141450...

Sent: 2/12/2025 12:59:27 PM

Viewed: 2/12/2025 1:22:34 PM

Signed: 2/12/2025 1:22:58 PM

Signature Adoption: Pre-selected Style

Using IP Address: 63.194.190.100

Electronic Record and Signature Disclosure:

Accepted: 5/11/2022 7:47:21 AM

ID: 050883f5-a40c-4427-bdbd-fa282a697a25

CBD eSignature

cbd.esignature@santacruzcountyca.gov

County of Santa Cruz

Security Level: Email, Account Authentication (None)



Using IP Address: 63.194.190.100

Sent: 2/12/2025 1:23:00 PM

Viewed: 2/12/2025 1:25:20 PM

Signed: 2/12/2025 1:25:44 PM

Freeform Signing

Electronic Record and Signature Disclosure:

Accepted: 6/20/2024 3:08:48 PM

ID: 4b7794de-1393-406f-a9a3-56a92d4b90d7

In Person Signer Events

Signature

Timestamp

Editor Delivery Events

Status

Timestamp

Agent Delivery Events

Status

Timestamp

Intermediary Delivery Events

Status

Timestamp

Certified Delivery Events	Status	Timestamp
Carbon Copy Events	Status	Timestamp
Sierra Ryan Sierra.Ryan@santacruzcountyca.gov Security Level: Email, Account Authentication (None) Electronic Record and Signature Disclosure: Accepted: 8/9/2024 9:21:30 AM ID: cc5ec81e-4117-4985-8706-a9fc0ef2149d	<div>COPIED</div>	Sent: 2/12/2025 1:25:47 PM Resent: 2/12/2025 1:27:34 PM
Witness Events	Signature	Timestamp
Notary Events	Signature	Timestamp
Envelope Summary Events	Status	Timestamps
Envelope Sent	Hashed/Encrypted	2/12/2025 12:03:35 PM
Envelope Updated	Security Checked	2/12/2025 1:27:34 PM
Certified Delivered	Security Checked	2/12/2025 1:25:20 PM
Signing Complete	Security Checked	2/12/2025 1:25:44 PM
Completed	Security Checked	2/12/2025 1:27:35 PM
Payment Events	Status	Timestamps
Electronic Record and Signature Disclosure		

ELECTRONIC RECORD AND SIGNATURE DISCLOSURE

From time to time, County of Santa Cruz (we, us or Company) may be required by law to provide to you certain written notices or disclosures. Described below are the terms and conditions for providing to you such notices and disclosures electronically through the DocuSign system. Please read the information below carefully and thoroughly, and if you can access this information electronically to your satisfaction and agree to this Electronic Record and Signature Disclosure (ERSD), please confirm your agreement by selecting the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

Getting paper copies

At any time, you may request from us a paper copy of any record provided or made available electronically to you by us. You will have the ability to download and print documents we send to you through the DocuSign system during and immediately after the signing session and, if you elect to create a DocuSign account, you may access the documents for a limited period of time (usually 30 days) after such documents are first sent to you. After such time, if you wish for us to send you paper copies of any such documents from our office to you, you will be charged a \$0.00 per-page fee. You may request delivery of such paper copies from us by following the procedure described below.

Withdrawing your consent

If you decide to receive notices and disclosures from us electronically, you may at any time change your mind and tell us that thereafter you want to receive required notices and disclosures only in paper format. How you must inform us of your decision to receive future notices and disclosure in paper format and withdraw your consent to receive notices and disclosures electronically is described below.

Consequences of changing your mind

If you elect to receive required notices and disclosures only in paper format, it will slow the speed at which we can complete certain steps in transactions with you and delivering services to you because we will need first to send the required notices or disclosures to you in paper format, and then wait until we receive back from you your acknowledgment of your receipt of such paper notices or disclosures. Further, you will no longer be able to use the DocuSign system to receive required notices and consents electronically from us or to sign electronically documents from us.

All notices and disclosures will be sent to you electronically

Unless you tell us otherwise in accordance with the procedures described herein, we will provide electronically to you through the DocuSign system all required notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you during the course of our relationship with you. To reduce the chance of you inadvertently not receiving any notice or disclosure, we prefer to provide all of the required notices and disclosures to you by the same method and to the same address that you have given us. Thus, you can receive all the disclosures and notices electronically or in paper format through the paper mail delivery system. If you do not agree with this process, please let us know as described below. Please also see the paragraph immediately above that describes the consequences of your electing not to receive delivery of the notices and disclosures electronically from us.

How to contact County of Santa Cruz:

You may contact us to let us know of your changes as to how we may contact you electronically, to request paper copies of certain information from us, and to withdraw your prior consent to receive notices and disclosures electronically as follows:

To contact us by email send messages to: nada.algharib@santacruzcounty.us

To advise County of Santa Cruz of your new email address

To let us know of a change in your email address where we should send notices and disclosures electronically to you, you must send an email message to us at nada.algharib@santacruzcounty.us and in the body of such request you must state: your previous email address, your new email address. We do not require any other information from you to change your email address.

If you created a DocuSign account, you may update it with your new email address through your account preferences.

To request paper copies from County of Santa Cruz

To request delivery from us of paper copies of the notices and disclosures previously provided by us to you electronically, you must send us an email to nada.algharib@santacruzcounty.us and in the body of such request you must state your email address, full name, mailing address, and telephone number. We will bill you for any fees at that time, if any.

To withdraw your consent with County of Santa Cruz

To inform us that you no longer wish to receive future notices and disclosures in electronic format you may:

- i. decline to sign a document from within your signing session, and on the subsequent page, select the check-box indicating you wish to withdraw your consent, or you may;
- ii. send us an email to nada.algharib@santacruzcounty.us and in the body of such request you must state your email, full name, mailing address, and telephone number. We do not need any other information from you to withdraw consent.. The consequences of your withdrawing consent for online documents will be that transactions may take a longer time to process..

Required hardware and software

The minimum system requirements for using the DocuSign system may change over time. The current system requirements are found here: <https://support.docusign.com/guides/signer-guide-signing-system-requirements>.

Acknowledging your access and consent to receive and sign documents electronically

To confirm to us that you can access this information electronically, which will be similar to other electronic notices and disclosures that we will provide to you, please confirm that you have read this ERSD, and (i) that you are able to print on paper or electronically save this ERSD for your future reference and access; or (ii) that you are able to email this ERSD to an email address where you will be able to print on paper or save it for your future reference and access. Further, if you consent to receiving notices and disclosures exclusively in electronic format as described herein, then select the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

By selecting the check-box next to 'I agree to use electronic records and signatures', you confirm that:

- You can access and read this Electronic Record and Signature Disclosure; and
- You can print on paper this Electronic Record and Signature Disclosure, or save or send this Electronic Record and Disclosure to a location where you can print it, for future reference and access; and
- Until or unless you notify County of Santa Cruz as described above, you consent to receive exclusively through electronic means all notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you by County of Santa Cruz during the course of your relationship with County of Santa Cruz.